



HCM4

Thermal **Energy**
Calculating Meter Systems For
'The Digital Age'

HCM4006 - Thermal Energy Calculating Meter - 230volts With Pulsed Output

Calculates The Energy Used In Heating or Cooling Systems
KWh & Monetary Read Outs (£ \$ E)
Digital High Accuracy Sensors
Strap On Pockets
'On Site' Programming Facility
Manufactured to ISOEN 1434 Parts 1 to 6
Conforms to the Measuring Instruments Directive (MID) 2004)



Support British Manufacturing
This product has been designed and
is totally manufactured in the UK

CE



He read the Instructions



He **DIDN'T** !!!!

HCM4

Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

The HCM4 consists of 4 component parts

- 1 – The HCM4 Energy Calculating Meter
- 2 – A Set (of two) Digital High Accuracy Digital DHAS sensors
- 3 – A Set (of two) 'Strap On' Pockets – The temperature sensor bulbs can be strapped directly onto the pipe work .
- 4 – Flow Meter and Thermal Jacket

Mounting

The HCM4 is designed for wall mounting, a screw case hanging position is located at the top centre of the case with two wall fixing positions located under the terminal cover

Wiring

Wiring block list -- terminals are marked on the pcb –
Remove Meter front cover to expose wiring block

Wiring Terminal List

1 = Power In (+) - 230v

2 = Power In (-) - 230v

3 = Sensor Hot -- Brown

4 = Sensor Hot -- Green

5 = Sensor Hot -- Blue

6 = Flow Meter 1 (+) (The red led on front of case flashes when it receives a pulse from the flow meter)

7 = Flow Meter 1 (-)

8 = Pulsed Output 1 (+)

9 = Pulsed Output 1 (-)

10 = Analog Output (4 - 20 mA) 1 Active (where fitted)

11 = Analog Output (4 - 20 mA) 2 (where fitted)

12 = Analog Output (4 - 20 mA Passive (where fitted)

13 =

14 =

16 = Pulsed Output 2 (-) -- (where fitted)

17 = Flow Meter 2 (+) -- (where fitted)

18 = Flow Meter 2 (-) -- (where fitted)

19 = Sensor Cold -- Brown

20 = Sensor Cold -- Green

21 = Sensor Cold -- Blue



Installation Tip

Fit sensors and wire in
before powering up


Separate PCB For Mbus – Two Wires

M Bus Set Up
Primary Addressing
Baud Rate 300
Meter ID – On Front Label
M Bus - Status 0 = Normal
M Bus – Status 1 = Fault

HCM4

Thermal **Energy**
Calculating Meter Systems For
'The Digital Age'

HCM4006 – Wiring (M Bus)



Suggested Wiring - Mbus


All electrical Installation's must conform to BS7671 IEE Wiring Regulations

Below Ground - Armoured - Basec Approved - Low Voltage Armoured 2 Core - XLPE Insulated to BS 6724

Above Ground - Low Resistance Speaker Cable Two Core Conductor 0.75mm (Not Sheathed)

HCM4

Thermal **Energy** Calculating Meter Systems For 'The Digital Age'



Installation

Remove HCM4 cover and install all wiring leaving the **connection of either mains supply 230v or 24v**

Wiring standards must conform to IEE regulations

It is recommended to use shielded cable manufactured to BS4360 Class 5 or VDE0295 Class 5

It is recommended that the flow meter when in a heating circuit is fully insulated with a Thermal Jacket



HCM4

Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

DHAS Sensors (Digital High Accuracy Sensors)

Are highly accurate, temperature thermometers, they are calibrated to an accuracy of 1.0% and a calibration certificate is included with each sensor set. DHAS are highly efficient and flexible.

The **Red Coloured Sensor bulb**, should always be located in the hottest pipe

Heating Circuit = Flow Chilled Circuit = Return

The **Black Coloured Sensor bulb**, should always be located in the coolest pipe

Heating Circuit = Return Chilled Circuit = Flow

DHAS Sensors (Digital High Accuracy Sensors)

DHAS Sensors are highly accurate, calibrated temperature sensors, there unique design ensures they can be easily strapped onto the pipe work. The sensors have individual serial numbers located on the cable, and a calibration certificate is supplied with each set. Unlike other similar products DHAS sensors are both flexible and reliable. And are extremely installer friendly

A – They do not have to be a matched pair

B – They can be cut in length without effecting calibration

LD (Long Distance) Temperature Sensors

All versions of HCM's, owing to there digital design, have the unique ability to be able to read data securely with 100% accuracy over long distances, Temperature sensors that can measure accurately for distances up to 200 metres.

Sensors can be purchased in the following sizes –

Order Code 404020 5metres Order Code 404030 10 metres

Order Code 404040 50 metres Order Code 404050 100 metres

Order Code 404060 150 metres Order Code 404070 200 metres

(other sizes by request)

Programming Heat Calculator

At Boot up - Sequence

Matrix Metering

HCM4006 Version No 2.8

Boot Up –

Is split into 4 sections each section scroll (Left/Grey Button) and Accept with (Right/Blue Button)



Installation Tip
Buttons
Left/Grey = Scroll
Right /Blue = Accept

1st Screen Set (Setting of Energy Unit)

Energy in KW/KWh

Energy in MW/MWh

Total Billing Counter either Kilowatt hours (standard) or Megawatt Hours (commercial)

HCM4

Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

2nd Screen Set (Billing Preference) 2/a



Resetable Energy

Billing in KWh's

If this option chosen

Resetable Money

Billing in Monetary Value

Screen 2/b

Cost 000.p KWh

See Page 8
For full
explanation



3rd Screen Set (What type of system is it)

Heating System

Heating/Central Heating/Hot Water

Cooling System

Cooling/Chilled/Air Conditioning

4th Screen Set (Where is the flow meter located)

Meter in Return

Meter in Flow

Where is the flow/water meter located – Return pipe (standard) or Flow pipe

5th Screen Set (Pulse value from Water Meter)

F1 0001 L/pulse

F1 0100 L/pulse

Pulse value selectable 1,10,100,1000 litres per pulse

Example F10 = 10 litres of water per pulse

(The pulse value is always located on the meter)

Thermal **Energy**
Calculating Meter Systems For
'The Digital Age'

END OF PROGRAMMING

**THE HCM4 NOW AUTOMATICALLY SCROLLS
THROUGH THE SETTINGS**



6th Screen Set

Reject Settings

Accept Settings

THIS STAGE IS VERY IMPORTANT

If during the auto scroll you are unsure of the setting – press Reject Settings and start again

Should you be sure the settings are correct - press Accept Setting

7th Screen Set

Hold to Save ..

You will need to hold the Blue/Right button down firmly for 10secs – the buzzer will sound continuously

Last screen

Saved

At this point all the settings are saved

Operational Data

Default Screen



See Page 8
For full explanation

RM £ 050.25

Resettable Money

RE 45697.1 KWh

Resettable Energy KWh/MWh

Total

TE 0000000.0 KWh

Total consumption in KWh's (or MWh's) Nine digits + One 1/10 (NOT reset table)

**Instantaneous
Energy**

IE 23 KW

The amount of energy being consumed in the circuit NOW

**Temperature
Flow**

tf 78.8C

HCM4

Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

Temperature in the flow pipe

**Temperature
Return**

tr	78.8C
----	-------

Temperature in the return pipe

Flow

F1	354.87 m3/h
----	-------------

Total flow in metres cubed per hour 1 m3h = 3.6 litres

To Change Settings

Once passed screen set no 7 – the only way to access the settings is with a Zapper Unit
Reference www.hcm4.com/zapper.htm

Outward Pulse Data – Open Collector

Maximum Operating Voltage 45vdc
Clamp circuit interjection 65vdc
500watt Power Dissipation Limit - Max Current 10amp
Reverse Connection Protection 6vdc
Pulse Width 200 ms
DC Forward Current 0.6v
Rise And Fall Max 18 micro Secs
Isolation Résistance 5 x 10/10 ohms
Isolation Voltage 5 kV
Collector Remitter Saturation Voltage 0.4volts
Operating temperature range -55c to 130c

Outward Pulse Value

10 pulses per KWh (if set for KWh's)

OR

10 pulses per MWh (if set for MWh's)



EXPLANATIONS & FAQ's

(Ref 2nd Screen Setting) Reset able Energy (A) or Monetary Value (B)

This offers the option of either having the default screen showing as :-

**A Energy -- Shown as KWh (standard applications) or
MWh (Commercial Applications)**

B Monetary Value -- Shows the value as real money !!!

Q1 -- Can I reset the screens

A1 -- Yes with a IT – Reset Zapper unit

Q2 -- Do I lose all the data at reset

A2 -- No the system integrity is kept,the 2nd screen in operation retains the total usage since start and is not resettable



Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

Q3 -- What security of settings are there

A3 -- Once the settings have been saved (9th Screen) they cannot be tampered with

Q4 -- How can I change the settings and monetary values

A4 -- Security is important for this reason we have developed a zapper unit



The zapper www.hcm4.com/zapper.htm unit will open the software for settings and monetary value resetting. The company registers each zapper unit sold

Q5 -- What is shown on the screen when in operation

A5 -- The current total which can be reset – either KWh's or Monetary value

Q6 – I am trying to set up a HCM and I keep getting '**POWER FAILURE**' on the display .

A6 -- The sensors are either incorrectly wired – re check the wiring – or damaged- replace.




Q7 – **Reverse Energy** is on the display ?

A7 – This appears when there isn't a 1c difference between flow & return pipe temperatures.

Display – Dim or Showing Blocks Only = Display Dislodged
Pull display out of its socket and replace carefully



Display Socket



Metal Strips in ribbon cable and pins in socket need to be in line

Cable requires to be mounted to the left of the socket

HCM4

Thermal **Energy** Calculating Meter Systems For *'The Digital Age'*

Error Codes

- Act as a 'Que' in the software to inform of potential problems. When an 'ERROR' occurs the HCM4's buzzer operates.

ERROR 1 No sensors connected or shorted to 5volts
 ERROR 2 Data shorted to 0 volts
 ERROR 3 Data transmission error
 ERROR 4 Only 1 sensor connected
 ERROR 5 Not a pair (either 2 hot or two cold connected)
 FREEZING Temperature in pipes or below 1c NEGATIVE DELTA T The sensors are likely too be the wrong way round

Guarantee

All products are guaranteed on a return to base basis only, for a period of 12 months from dispatch date. No compensation can be offered, relating to consequential loss.

Where HCM4 Calculators are installed, not using Meters UK water/flow meters

This could alter the known operational criteria, and effect the product integrity. The company reserve the rights to refuse claims where deemed correct.

This product is sold subject to the company Despatch, Guarantee & Returns Policy only

www.meters.co.uk/policy.htm

Other M Bus Devices

Shara 100

M Bus Converter -

Converts Pulsed Outputs Into M Bus

Electricity – Gas – Water Meters

M-Bus



M Bus Masters

Available In

10 Ports
 32 Ports
 64 Ports
 128 Ports
 250 Ports

meters uk Ltd

An Accredited Low Carbon Company

Whitegate, White Lund Trading Estate, Lancaster,
 Lancashire, UK, LA3 3BT Tel 01524 555929 Fax 01524 847009

e mail sales@meters.co.uk